



1826 Kramer Lane, Suite M
Austin, Texas 78758
p | 512-926-6650
f | 512-833-5058
kleinfelder.com

To: Austin Aggregates
Attn.: Mr. Troy Carter
P.O. Box 27935
Austin, Texas 78755

Project: 2009 Austin Aggregates QA

Project No.: 104637
Date: 6-19-09
Control No.: 061608 B


Page 1 of 1

REPORT OF: Sieve Analysis of Fine Aggregates
TEST METHOD: ASTM C-136
LAB ID NUMBER: G-2347
MATERIAL DESCRIPTION: Masonry Sand
MATERIAL SOURCE: Plant Stockpile
SAMPLED BY: D. Potteiger, ACI #01147441
DATE RECEIVED: 6-16-09
TEST PERFORMED BY: D. Potteiger, ACI #01147441
RESULTS:

<u>Sieve Size</u>	<u>Percent Passing</u>	<u>ASTM C-144</u>
#4	100	100
#8	99.9	95-100
#16	97.4	70-100
#30	74.3	40-75
#50	21.8	10-35
#100	4.7	2-15
#200	0.8	0-5

Report Reviewed by: gmf

1-Above


Robert S. Wright, P.E.