



1826 Kramer Lane, Suite M
Austin, Texas 78758
p | 512-926-6650
f | 512-833-5058
kleinfelder.com

To: Austin Aggregates
Attn.: Mr. Troy Carter
P.O. Box 27935
Austin, Texas 78755

Project: 2009 Austin Aggregates QA

Project No.: 104637
Date: 06-25-09
Control No.: 061608 F

Page 1 of 1

REPORT OF: Sieve Analysis of Fine Aggregates
TEST METHOD: TEX-401A
LAB ID NUMBER: G-2348
MATERIAL DESCRIPTION: Utility Sand
MATERIAL SOURCE: Plant Stockpile
SAMPLED BY: Daren Potteiger, ACI #01147441
DATE RECEIVED: 06-16-09
TEST PERFORMED BY: Pulasthi Rajapakse, ACI #01018496
RESULTS:

<u>Sieve Size</u>	<u>Percent Retained</u>	<u>COA Item 510</u>
1/4"	0	0
#60	85.7	75-100
#100	97.7	95-100

1-Above

Report Reviewed by: ABD

R.S. Wright
Robert S. Wright, P.E.