



1826 Kramer Lane, Suite M
 Austin, Texas 78758
 p | 512-926-6650
 f | 512-833-5058
 kleinfelder.com

To: Austin Aggregates
 Attn.: Mr. Troy Carter
 P.O. Box 27935
 Austin, Texas 78755

Project: 2010 Austin Aggregates QA

Project No.: 109970
 Date: 07-15-10
 Control No.: 071507 A

REPORT OF: Sieve Analysis of Coarse Aggregates
 TEST METHOD: ASTM C-136
 LAB ID NUMBER: G-2801
 MATERIAL DESCRIPTION: 2" x 1" Gravel
 MATERIAL SOURCE: Plant Stockpile
 SAMPLED BY: K. Woodard, NICET II #107418
 DATE RECEIVED: 07-13-10
 TEST PERFORMED BY: D. Pottleiger, ACI #01147441; K. Eidenschink
 RESULTS:

Sieve Size	Percent Passing	ASTM C-33 Gr. 3
2 1/2"	100	100
2"	99.6	90-100
1 1/2"	68.8	35-70
1"	9.0	0-15
3/4"	1.1	--
1/2"	0.4	0-5
3/8"	0.3	--

Report Reviewed by: PHB

Mark Holcomb, C.E.T.

1-Above