



1826 Kramer Lane, Suite M
Austin, Texas 78758
p | 512-926-6650
f | 512-833-5058
kleinfelder.com

To: Austin Aggregates
Attn.: Mr. Troy Carter
P.O. Box 27935
Austin, Texas 78755

Project: 2010 Austin Aggregates QA

Project No.: 109970
Date: 07-15-10
Control No.: 071507 B

Page 1 of 1

REPORT OF: Sieve Analysis of Fine Aggregates
TEST METHOD: ASTM C-136
LAB ID NUMBER: G-2800
MATERIAL DESCRIPTION: Masonry Sand
MATERIAL SOURCE: Plant Stockpile
SAMPLED BY: K. Woodard, NICET II #107418
DATE RECEIVED: 07-13-10
TEST PERFORMED BY: D. Potteiger, ACI #01147441
RESULTS:

<u>Sieve Size</u>	<u>Percent Passing</u>	<u>ASTM C-144</u>
#4	100	100
#8	99.9	95-100
#16	96.9	70-100
#30	71.7	40-75
#50	32.1	10-35
#100	7.3	2-10
#200	0.9	0-5

Report Reviewed by: *JBD*

Mark Holcomb, C.E.T.

1-Above