



1826 Kramer Lane, Suite M
 Austin, Texas 78758
 p | 512-926-6650
 f | 512-833-5058
 kleinfelder.com

To: Austin Aggregates
 Attn.: Mr. Troy Carter
 P.O. Box 27935
 Austin, Texas 78755

Project: 2010 Austin Aggregates QA


Project No.: 109970
 Date: 7-06-10
 Control No.: 062814 B


REPORT OF: Sieve Analysis, Specific Gravity, Unit Weight, and Decantation
 TEST METHOD: ASTM C136, C127, C29, C117
 LAB ID NUMBER: G-2784
 MATERIAL DESCRIPTION: 3/8" Pea Gravel
 MATERIAL SOURCE: Plant Stockpile
 SAMPLED BY: K. Woodard, NICET II #107418
 DATE SAMPLED: 6-28-10
 TEST PERFORMED BY: D. Potteiger, ACI #01147441
 RESULTS:

<u>Sieve Size</u>	<u>Percent Passing</u>	<u>ASTM C-33, Grade 8 Specifications</u>
1/2"	100	100
3/8"	92.1	85-100
#4	17.5	10-30
#8	0.8	0-10
#16	0.5	0-5
#50	0.4	--

Specific Gravity.....2.595
 Absorption, %1.3
 Oven Dry Loose Unit Weight, pcf.....94.1
 Oven Dry Rodded Unit Weight, pcf....100.8
 Decantation, %.....0.3

1-Above

Reviewed by: 



Mark Holcomb, C.E.T.