



1826 Kramer Lane, Suite M
Austin, Texas 78758
p | 512-926-6650
f | 512-833-5058
kleinfelder.com

To: Austin Aggregates
Attn.: Mr. Troy Carter
P.O. Box 27935
Austin, Texas 78755


Project: 2010 Austin Aggregates QA

Project No.: 109970
Date: 7-06-10
Control No.: 062814 F

REPORT OF: Sieve Analysis of Fine Aggregates
TEST METHOD: TEX-401A
LAB ID NUMBER: G-2785
MATERIAL DESCRIPTION: Utility Sand
MATERIAL SOURCE: Stockpile
SAMPLED BY: K. Woodard, NICET II #107418
DATE RECEIVED: 6-28-10
TEST PERFORMED BY: D. Potteiger, ACI #01147441
RESULTS:

<u>Sieve Size</u>	<u>Percent Retained</u>	<u>COA Item 510</u>
1/4"	0	0
#60	83.9	75-100
#100	96.3	95-100

Report Reviewed by: 



Mark Holcomb, C.E.T.