

**TO:** A.R.M. (Austin Reclaimed Materials)  
Attn.: Mr. Troy Carter  
P.O. Box 27935  
Austin, Texas 78755

**PROJECT:** 2006 Annual A.R.M.


**PROJECT NO.:** 66166  
**DATE:** 2-9-07  
**CONTROL NO.:** 020613 C

**Test Method:** ASTM D 698-00  
**Sample Number:** S-16482  
**Sample Location:** Naumann Pit  
**Sampled By:** Client  
**Date Sampled:** 2-6-07  
**Test Method:** ASTM D 4318-00  
ASTM D 2487-00  
ASTM D 1140-00

**Material Description:** "N" Loam  
(Dark Brown Lean Clay -  
with Sand)

**Liquid Limit:** 37  
**Plastic Limit:** 16  
**Plasticity Index:** 21  
**Retained on 3":** 0  
**Retained on #4:** 0  
**Retained on #40:** 0.9  
**Retained on #200:** 17.7  
**Group Symbol:** CL

**Preparation Method:** Moist  
**Rammer:** Mechanical  
**Compaction Method:** A  
**Oversize Sieve :** #4  
**% By Weight Oversize:** NA  
**Bulk Specific Gravity:** NA



**Compaction Test**

**Lab Compacted Samples (Finer Fraction)**  
Maximum Dry Unit Weight (pcf): 109.2  
Optimum Moisture Content (%): 16.3

COPIES TO: 1-Above

Reviewed By: GM

Daren Potteiger  
Daren Potteiger