



# KLEINFELDER

An employee owned company

3601 Manor Road, Austin, Texas 78723 512/926-6650

**To:** A.R.M. (Austin Reclaimed Materials)  
Attn.: Mr. Troy Carter  
P.O. Box 27935  
Austin, Texas 78755

**Project:** 2006 Annual A.R.M.

**Project No.:** 66166

**Date:** 01-18-07

**Control No.:** 121933 E

REPORT OF: Sieve Analysis  
TEST METHOD: ASTM C-136  
LAB ID NUMBER: G-1390  
MATERIAL DESCRIPTION: 3/8" Pea Gravel  
MATERIAL SOURCE: Plant  
SAMPLED BY: R. Mendiola  
DATE SAMPLED: 12-19-06  
TEST PERFORMED BY: W. McClain  
RESULTS:

Sieve Size	Percent Passing	ASTM C-33, Grade 89 Requirements
1/2"	100	100
3/8"	93.6	90-100
#4	35.0	20-55
#8	5.1	5-30
#16	0.9	0-10
#50	0.4	0-5

1-Above  
1-KA Website

Report Reviewed by: GME

Daren Potteiger