

KLEINFELDER

EXPECT MORE®

AN EMPLOYEE OWNED COMPANY

3601 Manor Road / Austin, Texas
512-926-6650 / fax 512-926-3312
www.kleinfelder.com

To: A.R.M. (Austin Reclaimed Materials)
Attn.: Mr. Troy Carter
P.O. Box 27935
Austin, Texas 78755

Project: 2006 Annual A.R.M.

Project No.: 66166

Date: 1-29-07

Report No.: 121933 F

REPORT OF: Sieve Analysis,
TEST METHOD: TEX 401A
LAB ID NUMBER: G-1389
MATERIAL DESCRIPTION: 1" Utility Gravel
MATERIAL SOURCE: Plant
SAMPLED BY: R. Mendiola
DATE SAMPLED: 12-19-06
TEST PERFORMED BY: P. Rajapakse
RESULTS:

<u>Sieve Size</u>	<u>Percent Retained</u>	<u>COA Item 510 Requirements</u>
1 1/2"	0	0
1"	5.9	0-10
1/2"	83.3	40-85
#4	98.3	90-100
#8	99.2	95-100

Report Reviewed by: *GMF*

Daren Potteiger

Daren Potteiger

The results shown on this report are for the exclusive use of the client for whom they were obtained and apply only to the samples tested and/or inspected. They are not intended to be indicative of the qualities of apparently identical products. The use of our name must receive our prior written approval. Reports must be reproduced in their entirety.